

Auriga Research Pvt. Ltd.



DC Complex, Vill. Bagbania, P.O. Manpura, Teh. Nalagarh. Distt. Solan, Himach

Tele: +91-9318759781-82

e-mail: baddi@aurigaresearch.com, Website:www.aurigaresearch.com

Certificate of Analysis

Sample

BORE WELL WATER

Mfg. By

NS

Supplied By Submitted By NS

SAI BLITE INTERNATIONAL SCHOOL

Address Batch No. Dharampur Subathu Road, Dharampur Himachal Pradesh., Kasauli, HIMACHAL PRADESH- 173209 INDIA

NS

Mfg. Date

Expiry Date NS

Batch Size NS

Recd. On

Ref. No.

Mfg lic. No.

Sample Quantity

2 Ltr

BD202207070118

: 07/07/2022

: NS

: NS

<Test>

NS

<Results>

<Acceptable Limit>

<LLOQ>

<Permissible Limit>

<Method>

Date of start of analysis

07/07/2022

Date of completion of analysis

08/07/2022

Sample not drawn by laboratory.

Reference to protocol

:- IS 10500:2012 (Amendment No. 3, Feb 2021)

1 Description

Clear colourless

NS

liquid

TABLE 1. ORGANOLEPTIC AND PHYSICAL PARAMETERS

| 2 Odour | Agreeable | Agreeable | - | Agreeable | IS 3025(P-5):2018 |
|-------------------------------|------------|-----------|---|-----------|--------------------|
| 3 pH Value | 6.68 | 6.5-8.5 | - | - | IS:3025(P-11)-1983 |
| 4 Total Dissolved Solids,mg/L | 200.7 mg/l | 500 Max. | - | 2000.0Max | IS:3025(P-16)-1984 |

TABLE 2. GENERAL PARAMETERS CONCERNING SUBSTANCES UNDESIRABLE IN EXCESSIVE AMOUNTS (mg/l)

| 5 Chloride (as CI) | 28.05 mg/l | 250 Max. | 1.0 | 1000.0Max | IS:3025(P-32)1988 | | | |
|--------------------------------------------------------|--------------|-----------|--------|-----------|---------------------|--|--|--|
| 6 Fluoride (as F) | Not detected | 1.0 Max. | 0.050 | 1.50Max | IS:3025(P-60)2008 | | | |
| 7 Residual Free Chlorine | Not detected | 0.2 Min. | 0.050 | 1.0Max | IS:3025(P-26)1986 | | | |
| 8 Nitrate (as NO3) | 29.12 mg/l | 45 Max. | 1.0 | <u>=</u> | IS:3025(P-34)1988 | | | |
| 9 Sulphate (as SO4). | 35.55 mg/l | 200 Max. | 1.0 | 400.0Max | IS:3025(P-24)1986 | | | |
| 10 Total Alkalinity (as CaCO3) | 96.04 mg/l | 200Max. | 1.0 | 600.0Max | IS:3025(P-23)1986 | | | |
| 11 Total Hardness (as CaCO3) | 25.42 mg/l | 200 Max. | 1.0 | 600.0Max | IS:3025 (P-21) 2009 | | | |
| TABLE 3. PARAMETERS CONCERNING TOXIC SUBSTANCES (mg/L) | | | | | | | | |
| 12 Arsenic (as As) TABLE 6: BACTERIOLOGICAL T | Not Detected | 0.01 Max. | 0.0020 | 0.050Max | IS 3025(P-65):2014 | | | |

13 Escherichia coli /100 ml. Not Detected Not detectable

IS:15185-2016 (RA 2021)

14 Coliform /100ml

Not Detected

Not detectable

IS:15185-2016 (RA

2021)

Report: In the opinion of undersigned the sample referred above conform to the IS 10500:2012 (Amendment No. 3, Feb 2021) in respect to the above test parameters.



Page 1 of 2

Date :-

Friday, Jul 08, 2022

d Signatory

Note: The results listed refer only to the tested sample and applicable parameter. Endorsement of products is neither inferred nor implied. This report is not to be reproduced wholly or in part and cannot be used as evidence in the court of Law and should not be used in advertising media without our special Permission in writing



Auriga Research Pvt. Ltd.

Govt. Approved Test House



DC Complex, Vill. Bagbania, P.O. Manpura, Teh. Nalagarh, Distt. Solan, Himach

Tele: +91-9318759781-82 e-mail: baddi@aurigaresearch.com, Website:www.aurlg@eportNorm

BD202207070118

: 07/07/2022

Certificate of Analysis

Sample

BORE WELL WATER

Mfg. By

NS

Supplied By Submitted By NS

SAI BLITE INTERNATIONAL SCHOOL Dharampur Subathu Road, Dharampur Himachal Pradesh,, Kasauli, HIMACHAL PRADESH- 173209 INDIA

Address **Batch No**

Mfg. Date

NS

Expiry Date

NS

Batch Size

Recd. On

Ref. No.

Mfg lic. No. : NS

Sample Quantity 2 Ltr

: NS

<Test>

NS

<Results>

<Acceptable Limit>

<LLOQ>

<Permissible Limit>

<Method>



To verify Report Scan this Code.